


- ➔ For generator applications: L1 120v must be fed from utility side not through generator power.
- ➔ 25a relays connected to remote start contacts in ATS. Can be NC or NO.
- ➔ Request appropriate switches (up to 3); all switches are interchangeable
- ➔ Ripple must be in a waterproof environment.
- ➔ Normal off-peak "not controlled" position is "a", or UP position.

TO SCHEDULE AN APPOINTMENT WHEN COMPLETE
 CALL 701-746-4461 OR 800-732-4373 AND ASK FOR
 ENERGY SERVICES

 <small>Your Touchstone Energy® Partner</small>		
ROA RIPPLE CONTROL		
DRAWN BY:	CAD NAME:	REV BY:
DATE:	SHEET OF	REV DATE: